

18. Daylight tube

McD BERL conducted an experiment with daylight tube by inserting highly reflective coated polycarbonate sheet into PVC pipes. This was fixed to the window pane to fetch the daylight into the building. Experimentation was successful and could measure 50-100 lux for 120 sqft office space using 200mm dia tube (peak time).

Many companies in the market supply these tube wells and can be integrated well in the early stage of the building design.



18.1

MCD BERL